


**SITE PLAN REVIEW  
PUBLIC WORKS DEPARTMENT**

*Engineering Division*

**February 11, 2021**



As per request from the Planning, Conservation & Development Department, the following are comments and concerns that our department has in reference to the following application

**Z 2021 -1 Saybrook Road**

---


Drainage calculations need to be submitted showing no increase in runoff where the site drainage is connected to the City system in Saybrook Road.

Entrances to the building should be shown. It appears that the only entrances are at the rear of the building. This would eliminate any handicap access from the front, or lower, parking lot.

Handicap spaces should show access to the sidewalk area.

Design of the retaining wall must done by a professional engineer.

DEPT. PLANNING & ZONING  
21 FEB 11 PM 4:18

  
\_\_\_\_\_  
Thomas Nigosanti, City Engineer