


**SITE PLAN REVIEW  
PUBLIC WORKS DEPARTMENT**

*Engineering Division*

**February 26, 2021**



As per request from the Planning, Conservation & Development Department, the following are comments and concerns that our department has in reference to the following application

*SE 2021-2*  
**~~SPR2020-22~~ & 20-02 FedEx**

---

Sheet DM-1:

Note saying "Remove and dispose of bituminous concrete curb" should refer to extruded concrete curb.

Sheet SP-1:

Note saying "Begin concrete curb, match to existing bituminous concrete curb" should refer to extruded concrete curb.

Note saying "Sawcut existing bituminous concrete pavement (Typ)" should say to cut along the curb line.

Sheet GD-2:

All rip-rap should be either Standard or Intermediate.

Retaining wall to be designed by a licensed Professional Engineer.

DEPT. PLANNING & ZONING  
21 FEB 26 PM 1:00

*Thomas Nigosanti*

---

Thomas Nigosanti, City Engineer